



**BUREAU
VERITAS**

Certificat de conformité

Demandeur: SMA Solar Technology AG
Sonnenallee 1
34266 Niestetal
Allemagne

Produit: Onduleurs Photovoltaïques (PV)

Modèle: STP 15000TL-30
STP 20000TL-30
STP 25000TL-30

À utiliser conformément aux réglementations:

Dispositif de coupure automatique avec une surveillance du réseau triphasé, conformément à C10/11 – 01.09.2019, pour des systèmes photovoltaïques avec un couplage parallèle triphasé, via un convertisseur dans l'alimentation électrique publique. Le dispositif de coupure automatique fait partie intégrante de ce convertisseur. Il remplace le appareil de déconnexion avec une fonction isolante, auquel le fournisseur du réseau de distribution peut accéder à tout moment.

Réglementations et normes appliquées:

EN 50549-1:2019-02

Exigences relatives aux centrales électriques destinées à être raccordées en parallèle à des réseaux de distribution - Partie 1: Raccordement à un réseau de distribution BT - Centrales électriques jusqu'au Type B inclus

C10/11:2019-09

Prescriptions techniques spécifiques de raccordement d'installations de production décentralisée fonctionnant en parallèle sur le réseau de distribution

Un échantillon représentatif des produits mentionnés ci-dessus correspond à la date de la délivrance de ce certificat en vigueur des exigences de sécurité technique et pour l'utilisation conformément à sa destination.

Numéro de rapport: 14TH0304-EN50549-1_0 **Programme de certification:** NSOP-0032-DEU-ZE-V01
Numéro de certificat: U20-0097 **Délivré le:** 2020-02-26

Organisme de certification



Holger Schaffer

Organisme de certification Bureau Veritas Consumer Products Services Germany GmbH accrédité par DIN EN ISO/IEC 17065
Une représentation partielle du certificat nécessite l'autorisation écrite de Bureau Veritas Consumer Products Services Germany GmbH

Appendix

Extract from test report according to EN 50549-1 / C10/11

Nr. 14TH0304-EN50549-1_0

Type Approval and declaration of compliance with the requirements of EN 50549-1 / C10/11.

Manufacturer / applicant:	SMA Solar Technology AG Sonnentallee 1 34266 Niestetal Germany		
Micro-generator Type	Grid-tied photovoltaic inverter		
Rated values	STP 15000TL-30	STP 20000TL-30	STP 25000TL-30
MPP DC voltage range [V]	240 – 800	320 - 800	390 - 800
Input DC voltage range [V]	240 – 1000	320 - 1000	390 - 1000
Input DC current [A]	nom. 2 x 16 max. 2 x 33		
Output AC voltage [V]	400 3 / N / PE @ 50 / 60 Hz		
Output AC current [A]	29	29	36,2
Output power [VA]	15	20	25
Firmware version	Beginnin with 03.10.04.R		
Measurement period:	2019-12-27 to 2020-02-26		

Description of the structure of the power generation unit:

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.

Setting of the interface protection:

Parameter	Max. disconnection time	Trip value
Over voltage (stage 1) ^a	0,2s	230V +10% (253V)
Over voltage (stage 2)	0,2s	230V +15% (264,5V)
Under voltage	0,2s	230V -20% (184V)
Over frequency	0,2s	50Hz +3% (51,5Hz)
Under frequency	0,2s	50Hz -5% (47,5Hz)
Reconnection settings for voltage	0,85Un (195,5V) ≤ U ≤ 1,10Un (253V)	
Reconnection settings for frequency	49,9 Hz ≤ f ≤ 50,1 Hz	
Reconnection time	≥ 60 s	
Active power gradient starting	20% P _{E_{max}} / per minute	
Active power gradient after tripping	10% P _{E_{max}} / per minute	
Permanent DC-injection	0,5% of rated inverter output current or 20mA	
Loss of mains according EN 62116 (LoM)	2,0 s	

Note:

^a Over voltage – stage1: 10 min-mean-value corresponding to EN 50160.

Default interface setting according to C10/11:2019-09 are used.

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 and C10/11:2019. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the EN 50549-1:2019 and C10/11:2019.