




Product Service

# CERTIFICATE

No. Z2 087869 0001 Rev.00

**Holder of Certificate:** **Approsud Environnement Sàrl**  
ZI La Coupe  
44 avenue Paul Sabatier  
11100 Narbonne  
FRANCE

**Certification Mark:**



**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262101501-00

**Valid until:** 2025-10-19

**Date,** 2021-02-02

( Zhulin Zhang )

# CERTIFICATE

No. Z2 087869 0001 Rev.00

## Model(s):

SLxxx-M6-120SW, xxx=345-375 in steps of 5;  
 SLxxx-M6-120BW, xxx=345-375 in steps of 5;  
 SLxxx-M6-120BB, xxx=345-375 in steps of 5;  
 SLxxx-M6-144SW, xxx=415-450 in steps of 5;  
 SLxxx-M6-144BW, xxx=415-450 in steps of 5;  
 SLxxx-M6-144BB, xxx=415-450 in steps of 5;  
 SLxxx-G1-60SW, xxx=315-330 in steps of 5;  
 SLxxx-G1-60BW, xxx=315-330 in steps of 5;  
 SLxxx-G1-60BB, xxx=315-330 in steps of 5;  
 SLxxx-G1-72SW, xxx=385-395 in steps of 5;  
 SLxxx-G1-72BW, xxx=385-395 in steps of 5;  
 SLxxx-G1-72BB, xxx=385-395 in steps of 5;  
 SLxxx-G1-120SW, xxx=320-350 in steps of 5;  
 SLxxx-G1-120BW, xxx=320-350 in steps of 5;  
 SLxxx-G1-120BB, xxx=320-350 in steps of 5;  
 SLxxx-G1-144SW, xxx=380-405 in steps of 5;  
 SLxxx-G1-144BW, xxx=380-405 in steps of 5;  
 SLxxx-G1-144BB, xxx=380-405 in steps of 5;  
 SLxxx-M2-60SW, xxx=280-310 in steps of 5;  
 SLxxx-M2-60BW, xxx=280-310 in steps of 5;  
 SLxxx-M2-60BB, xxx=280-310 in steps of 5;  
 SLxxx-M2-120SW, xxx=280-320 in steps of 5;  
 SLxxx-M2-120BW, xxx=280-320 in steps of 5;  
 SLxxx-M2-120BB, xxx=280-320 in steps of 5;  
 SLxxx-M2-72SW, xxx=335-375 in steps of 5;  
 SLxxx-M2-72BW, xxx=335-375 in steps of 5;  
 SLxxx-M2-72BB, xxx=335-375 in steps of 5;  
 SLxxx-M2-144SW, xxx=340-385 in steps of 5;  
 SLxxx-M2-144BW, xxx=340-385 in steps of 5;  
 SLxxx-M2-144BB, xxx=340-385 in steps of 5;  
 xxx is standing for rated output power at STC.

## Parameters:

Fire Safety Class:	Class C according to UL790.
Safety Class:	Class II
Max. System Voltage:	1000V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute. No.10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China.
Construction:	Framed, with Junction box, cable and connector.

## Tested according to:

IEC 61215-1:2016  
 IEC 61215-1-1:2016  
 IEC 61215-2:2016  
 IEC 61730-1:2016  
 IEC 61730-2:2016  
 EN 61215-1:2016  
 EN 61215-1-1:2016  
 EN 61215-2:2017  
 EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

## Production Facility(ies):

076053